



Sewage System Installation Report

File No. SS2017-0342
Roll No. 165142000136100

Sewage System Installation by: GOSTUN SAND & GRAVEL Date: OCT. 18, 2018

Approved Installation of the Sewage System Includes:

☒ New ☐ Repair/Alteration ☐ Replacement ☐ Tank ☐ Leaching Bed ☐ Tank & Leaching Bed
☐ Class 2 or 3 System: Size: _____ m² Configured As: Length _____ m x Width _____ m x Height _____ m

Wall Structure: _____ Type of Cover: _____
☐ Class 5 System: Holding Tank: _____ L Manufacturer: _____ ☐ Audible & Visual Alarm

Class 4 System:

☒ Septic Tank: Working Capacity 3600 L constructed of concrete/fiberglass/plastic; Manufacturer: NPCP
☒ Distribution System: INfiltration 36 fed by ☐ Gravity ☐ Pump ☐ Siphon

Conventional Trench System:		Type A Dispersal Bed/Area Bed:	
Total _____	Lineal Metres in _____ runs of _____ m	Stone Area _____ m ²	Sand Area _____ m ²
Filter Bed:		Type B Dispersal Bed:	
Filter Bed Area <u>22.75</u> m ²	# of Pods <u>1</u>	DBA _____ m ²	Linear Loading Rate _____ m
Expanded Contact Area <u>95.6</u> m ²		Configured As: _____ m x _____ m	

Loading Rate Area: 353.75 m² Imported ☐ Native ☒ 15 metre Mantle ☒ Constructed ☐ Native ☐ Not Applicable
Height of Stone/Chamber Raised Above Original Grade: 1.0 m ☐ Other: _____


Sewage System Installation is based on:

Total Daily Sewage Flow: 1600 L/day

☒ No. of Bedrooms: 3; Total No. of Fixture Units 15; Total Living Space 200 m²

☐ Commercial: _____

☒ Sewage System is not designed to receive backwash water from a water treatment device.



Under the Building Code Act, Ontario Regulation 332/12 as amended and subject to the limitations thereof, an Installation Permit is hereby issued to: DEBBIE FRODGE for the use and operation of the above-noted sewage system installed and inspected at: 2 MONCK ST. also known as Lot 7 Concession 11 Plan _____ Sublot/Part: _____ in the City of Kawartha Lakes.

Inspected and Issued By: [Signature] Date: NOV. 22, 2018

Note: No change can be made to any building(s) or structures in connection with which this sewage system is used, if the operation or maintenance of the sewage system will be effected, unless approval is obtained.