



Sewage System Installation Report

File No. 553017-0323
Roll No. 11657.21003036100

Sewage System Installation by: Young's Landscaping Date: Sept 26, 2017

Approved Installation of the Sewage System includes:

- ☐ New ☐ Repair/Alteration ☒ Replacement ☐ Tank ☐ Leaching Bed ☒ Tank & Leaching Bed
☐ Class 2 or 3 System: Size: _____ m² Configured As: Length _____ m x Width _____ m x Height _____ m
Wall Structure: _____ Type of Cover: _____
☐ Class 5 System: Holding Tank: _____ L Manufacturer: _____ ☐ Audible & Visual Alarm
☒ Class 4 System:
☐ Septic Tank: Working Capacity 4500 L constructed of concrete/fiberglass/plastic; Manufacturer: Brockline Concrete
☐ Distribution System: ABC 24; fed by ☐ Gravity ☒ Pump ☐ Siphon

☐ Conventional Trench System: Total _____ Linear Metres in _____ runs of _____ m	☐ Type A Dispersal Bed/Area Bed: Stone Area _____ m ² Sand Area _____ m ²
☒ Filter Bed: Filter Bed Area <u>32</u> m ² # of Pods <u>1</u> Expanded Contact Area <u>35.6</u> m ²	☐ Type B Dispersal Bed: DBA _____ m ² Linear Loading Rate _____ m Configured As: _____ m x _____ m

- ☒ Loading Rate Area: 345.0 m² ☐ Imported ☐ Native ☒ 15 metre Mantle ☒ Constructed ☐ Native ☐ Not Applicable
☐ Height of Stone/Chamber Raised Above Original Grade: 0.3 m ☐ Other: _____


Sewage System Installation is based on:

Total Daily Sewage Flow: 1600 L/day

☒ No. of Bedrooms: 3; Total No. of Fixture Units 11.5; Total Living Space 92.9 m²

☐ Commercial: _____

☒ Sewage System is not designed to receive backwash water from a water treatment device.



Under the Building Code Act, Ontario Regulation 332/12 as amended and subject to the limitations thereof, an Installation Permit is hereby issued to: _____ for the use and operation of the above-noted sewage system installed and inspected at: 551 Manor Rd also known as Lot _____ Concession _____ Plan 1164 Sublot/Part: 19+20 in the City of Kawartha Lakes.

Inspected and Issued By: [Signature] Date: Oct. 16, 2017

Note: No change can be made to any building(s) or structures in connection with which this sewage system is used, if the operation or maintenance of the sewage system will be effected, unless approval is obtained.