



Ministry of
the Environment

Well Tag No. (Place Sticker and/or Print Below)

A111045

Well Record
Regulation 903 Ontario Water Resources Act

Measurements recorded in: ☐ Metric ☒ Imperial

Page _____ of _____

Well Owner's Information

First Name [Redacted]	Last Name / Organization [Redacted]	E-mail Address [Redacted]	☐ Well Constructed by Well Owner
Mailing Address (Street Number/Name) 57 Manor Rd.		Municipality Cameron	Province ON
		Postal Code T0M 1B0	Telephone No. (inc. area code) [Redacted]

Well Location

Address of Well Location (Street Number/Name) 57 Manor Rd.		Township Fenelon	Lot Pt. 0	Concession 8
County/District/Municipality City of Kawartha Lakes (Victoria)		City/Town/Village Cameron	Province Ontario	Postal Code T0M 1B0
UTM Coordinates	Zone 17	Easting 68 0 41 5	Northing 49 24 7 39	Municipal Plan and Sublot Number
				Other

Overburden and Bedrock Materials/Abandonment Sealing Record (see instructions on the back of this form)

General Colour	Most Common Material	Other Materials	General Description	Depth (m/ft)
				From To
Brown	Clay	gravel		0 25
Gray	Clay	gravel		25 42
Gray	Limestone			42 60

Annular Space		
Depth Set at (m/ft)	Type of Sealant Used (Material and Type)	Volume Placed (m ³ /ft ³)
From To		
0 20	Bentonite slurry	

Method of Construction		Well Use	
☒ Cable Tool	☐ Diamond	☐ Public	☐ Commercial
☐ Rotary (Conventional)	☐ Jetting	☐ Domestic	☐ Municipal
☐ Rotary (Reverse)	☐ Driving	☐ Livestock	☐ Test Hole
☐ Boring	☐ Digging	☐ Irrigation	☐ Cooling & Air Conditioning
☐ Air percussion		☐ Industrial	
☐ Other, specify _____		☐ Other, specify _____	

Construction Record - Casing				Status of Well	
Inside Diameter (cm/in)	Open Hole OR Material (Galvanized, Fibreglass, Concrete, Plastic, Steel)	Wall Thickness (cm/in)	Depth (m/ft)	From	To
5 1/2"	Steel	.188	41	42	
6"	Openhole		42.8	60	

☒ Water Supply
☐ Replacement Well
☐ Test Hole
☐ Recharge Well
☐ Dewatering Well
☐ Observation and/or Monitoring Hole
☐ Alteration (Construction)
☐ Abandoned, Insufficient Supply
☐ Abandoned, Poor Water Quality
☐ Abandoned, other, specify _____
☐ Other, specify _____

Construction Record - Screen			
Outside Diameter (cm/in)	Material (Plastic, Galvanized, Steel)	Slot No.	Depth (m/ft)
			From To

Results of Well Yield Testing				
After test of well yield, water was: ☐ Clear and sand free ☐ Other, specify _____	Draw Down		Recovery	
	Time (min)	Water Level (m/ft)	Time (min)	Water Level (m/ft)
If pumping discontinued, give reason: _____	Static Level	17.2		
	1	19.7	1	29.2
Pump intake set at (m/ft) 55 ft.	2	21.5	2	27.7
Pumping rate (l/min / GPM) 5 gpm	3	23.0	3	26.2
Duration of pumping 1 hrs + _____ min	4	23.7	4	25.4
Final water level end of pumping (m/ft) 33.1 ft.	5	24.9	5	23.5
If flowing give rate (l/min / GPM)	10	26.0	10	22.0
	15	28.6	15	21.2
Recommended pump depth (m/ft) 55 ft.	20	29.3	20	20.3
	25	29.9	25	19.7
Recommended pump rate (l/min / GPM) 5 gpm	30	30.5	30	19.0
Well production (l/min / GPM)	40	31.2	40	18.7
	50	32.7	50	18.5
Disinfected? ☒ Yes ☐ No	60	33.1	60	18.1

Annular Space			
Depth Set at (m/ft)		Type of Sealant Used (Material and Type)	Volume Placed (m³/ft³)
From	To		
0	20	Bentonite slurry	

Method of Construction		Well Use	
☒ Cable Tool	☐ Diamond	☐ Public	☐ Commercial
☐ Rotary (Conventional)	☐ Jetting	☒ Domestic	☐ Municipal
☐ Rotary (Reverse)	☐ Driving	☐ Livestock	☐ Test Hole
☐ Boring	☐ Digging	☐ Irrigation	☐ Cooling & Air Conditioning
☐ Air percussion		☐ Industrial	
☐ Other, specify		☐ Other, specify	

Construction Record - Casing				Status of Well	
Inside Diameter (cm/in)	Open Hole OR Material (Galvanized, Fibreglass, Concrete, Plastic, Steel)	Wall Thickness (cm/in)	Depth (m/ft)		☐ Water Supply ☐ Replacement Well ☐ Test Hole ☐ Recharge Well ☐ Dewatering Well ☐ Observation and/or Monitoring Hole ☐ Alteration (Construction) ☐ Abandoned, Insufficient Supply ☐ Abandoned, Poor Water Quality ☐ Abandoned, other, specify ☐ Other, specify
			From	To	
6 1/2"	Steel	.189	+1 1/2	42	
6"	Openhole		42.5	60	

Construction Record - Screen				
Outside Diameter (cm/in)	Material (Plastic, Galvanized, Steel)	Slot No.	Depth (m/ft)	
			From	To

Water Details		Hole Diameter	
Water found at Depth (m/ft)	Kind of Water: ☐ Fresh ☒ Untested	Depth (m/ft)	Diameter (cm/in)
42.5	☐ Gas ☐ Other, specify	From	To
		0	20
Water found at Depth (m/ft)	Kind of Water: ☐ Fresh ☐ Untested		
	☐ Gas ☐ Other, specify	20	60
Water found at Depth (m/ft)	Kind of Water: ☐ Fresh ☐ Untested		
	☐ Gas ☐ Other, specify		

Well Contractor and Well Technician Information			
Business Name of Well Contractor		Well Contractor's Licence No.	
G. Hart & Sons Well Drilling Ltd.		2692	
Business Address (Street Number/Name)		Municipality	
Box 850, 142 County Rd 8		Fenelon Falls	
Province	Postal Code	Business E-mail Address	
ON	K0M 1N0		
Bus. Telephone No. (inc. area code)		Name of Well Technician (Last Name, First Name)	
705 887-8331		Lean Jim	
Well Technician's Licence No.	Signature of Technician and/or Contractor		Date Submitted
1-5545	<i>Lean Jim</i>		Y Y Y Y M M D D

Results of Well Yield Testing					
After test of well yield, water was:		Draw Down		Recovery	
☒ Clear and sand free ☐ Other, specify		Time (min)	Water Level (m/ft)	Time (min)	Water Level (m/ft)
If pumping discontinued, give reason:		Static Level	17.2		
Pump intake set at (m/ft)		1	19.7	1	29.2
55 ft.		2	21.5	2	27.7
Pumping rate (l/min / GPM)		3	23.0	3	26.2
Duration of pumping		4	24.8	4	24.3
1 hrs + min		5	24.8	5	23.5
Final water level end of pumping (m/ft)		10	29.0	10	22.0
33.1 ft.		15	28.6	15	21.2
If flowing give rate (l/min / GPM)		20	29.3	20	20.3
Recommended pump depth (m/ft)		25	29.4	25	19.7
55 ft.		30	30.5	30	19.0
Recommended pump rate (l/min / GPM)		40	31.2	40	19.7
5 gpm		50	32.7	50	18.3
Well production (l/min / GPM)		60	33.1	60	18.2
Disinfected?					
☒ Yes ☐ No					

Map of Well Location	
Please provide a map below following instructions on the back.	

Ministry Use Only	
Audit No.	
2142770	
Received	