

ONE STOP FIREPLACE (STOP) <sup>bellnet.ca</sup>

516080

DATE Sept 12/14  
 N° DE TAXE  
 TAX REG. NO.

705 786-7755

VENDU A SOLD TO <b>WOOD</b>	EXPÉDIER A SHIP TO
ADRESSE ADDRESS <b>85 SUGAR BUSH TRAIL FENELON FALLS</b>	ADRESSE ADDRESS <b>SERIAL # 246674</b>

COMMANDE DU CLIENT CUSTOMER'S ORDER	VENDU PAR SOLD BY	CONDITIONS TERMS	FAB FOB	VIA
--	-------------------	------------------	---------	-----

QUANTITE QUANTITY	DESCRIPTION	PRIX PRICE	UNITÉ UNIT	MONTANT AMOUNT
1	SUPER 27 WITH NICKEL LEGS NICKEL DOOR & ASH SYSTEM			2415 00
1	SET DOUBLE WALL PIPES			425 00
1	INSULATED THIMBLE			227 00
1	STAINLESS STEEL LINER			300 00
	LABOUR TO INSTALL			500 00
	DEP 2621.83 pd chg			3867 00
	BAL. 1747.88 pd chg # 052.			
			TPS/GST TVH/HST	502 71
			TVR/PST	
			TOTAL	4369 71

FACTURE INVOICE

ONE STOP FIREPLACE STOP  
 BOX 89 WITTLEBRITAIN ON  
 KOM 2 CO

681008

DATE Nov 11/14  
 N° DE TAXE  
 TAX REG. NO.

705 786-7755

VENDU A SOLD TO <b>WOOD</b>	EXPÉDIER A SHIP TO
ADRESSE ADDRESS <b>85 SUGAR BUSH TRAIL FENELON FALLS</b>	ADRESSE ADDRESS

COMMANDE DU CLIENT CUSTOMER'S ORDER	VENDU PAR SOLD BY	CONDITIONS TERMS	FAB FOB	VIA
--	-------------------	------------------	---------	-----

QUANTITE QUANTITY	DESCRIPTION	PRIX PRICE	UNITÉ UNIT	MONTANT AMOUNT
	CONNECT FLASHING & CAP & FINISH WEIT REPORT			150 00
	Pd Chg #56 Nov 17/14			
			TPS/GST TVH/HST	19 50
			TVR/PST	
			TOTAL	169 50

FACTURE INVOICE

Customer name RUTH WOOD  
 Address 85 SUGARBUSH TRAIL  
 Telephone FENSLON FALLS  
 Inspector BILL SHIRMAN

One Stop Fireplace Shop  
 Box 89 414 Eldon Road  
 Little Britain, Ontario  
 705-786-7755

### SPACE HEATER AND FLUE PIPE INSPECTION

Appliance Manufacturer PACIFIC ENERGY  
 Appliance Type WOODSTOVE Model SUPER 27  
 Certified  Yes  No Date of Installation NOV/14

	Required	Actual	Compliance	
Left	<u>16in</u>	<u>64in</u>	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Right	<u>16in</u>	<u>83in</u>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Front	<u>48in</u>	<u>48in</u>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Back	<u>5in</u>	<u>5.5in</u>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Top	<u>84in</u>	<u>94in</u>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Mantel	—	—	<input type="checkbox"/> Yes	<input type="checkbox"/> No

	Required	Actual	Compliance	
Shield Extension	—	—	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Sides & Back	—	—	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Ceiling Shield	—	—	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Floor Shield Type	—	—	<input type="checkbox"/> Yes	<input type="checkbox"/> No
" " Extension	—	—	<input type="checkbox"/> Yes	<input type="checkbox"/> No

Comments: \_\_\_\_\_

Floor Clearance 3/8  
 Floor Pad Dimension 49in x 42in  
 Material CERAMIC TILE

Compliance  Yes  No  
 Yes  No  
 Yes  No

	Standard	Required	Actual	Compliance
Sides and Rear	200 mm	<u>8in</u>	<u>9in</u>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Front Loading	450 mm	<u>18in</u>	<u>20in</u>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Flue Pipe Type ICC DOUBLE WALL  
 Diameter 6in Length 56in Gauge 24  
 Fasteners SCREWS  
 Inspection Wrap YES Pipe Damper NA  
 Condition good Compliance  Yes  No  
 Orientation — Male up  Male down   
 Rise Toward Chimney \_\_\_\_\_  Yes  No  
 Properly Supported \_\_\_\_\_  Yes  No  
 Pipe Length 56in Compliance  Yes  No  
 Number of 90° elbows 1  Yes  No

Flue Pipe Clearance  
 Required 6in Actual 12.5in  
 Shielding Material \_\_\_\_\_  
 Size \_\_\_\_\_ x \_\_\_\_\_ Clearance reduced to: \_\_\_\_\_  
 Compliance  Yes  No

Chimney Breech  
 Type ICC INSULATED  
 Condition good  
 Compliance  Yes  No  
 Comments \_\_\_\_\_

Up to TODAY'S CODE NOV 11/14  
 Bill Shirman WETT #1125

Customer Name RUTH WOOD  
 Address 85 SUGAR BUSH TRAIL  
 Telephone REVELON FALLS  
 Inspector BILL SHERMAN

One Stop Fireplace Shop  
 Box 89 414 Eldon Road  
 Little Britain, Ontario  
 705-786-7755

### CHIMNEY INSPECTION

#### MASONRY

Shell Material Brick  
 Foundation Type CONCRETE  
 Condition WFL Compliance  Yes  No  
 Total Chimney Height 20ft  
 Chimney Crown Type MORTAR  
 Condition good Compliance  Yes  No  
 Flashing Type METAL  
 Condition FAIR Compliance  Yes  No  
 Comments \_\_\_\_\_

#### Clearances Above Roof

	Required	Actual
Vertical	900 mm (36")	<u>48in</u>
Horizontal	3 m (10')	<u>10ft</u>

Chimneys must extend 600 mm (24") above obstacles within a horizontal distance of 3 m (10')  
 Compliance  Yes  No

#### Chimney Liner

Liner Type CLAY Cross-section 8 x 12  
 Height above crown 9in Offset 0"

#### Chimney Breech

Breech Type/Material STAINLESS STEEL  
 Condition good Compliance  Yes  No

#### Wall Pass-through

Type INSULATED  
 Condition \_\_\_\_\_ Compliance  Yes  No

#### Cleanout Door

Type \_\_\_\_\_  
 Location \_\_\_\_\_ Size \_\_\_\_\_ x \_\_\_\_\_

#### Clearances Below Roof

	Required	Actual
Inside	50 mm (2")	<u>WFL</u>
Outside	12 mm (1/2")	<u>WFL</u>

Compliance  Yes  No

#### FACTORY BUILT

Manufacturer \_\_\_\_\_  
 Type \_\_\_\_\_ Model \_\_\_\_\_  
 Total Height \_\_\_\_\_ Flue Size \_\_\_\_\_  
 Inside  Outside

#### Rain Cap

Condition \_\_\_\_\_ Compliance  Yes  No

#### Flashing

Condition \_\_\_\_\_ Compliance  Yes  No

#### Chimney Support

Adequate Base Support  Yes  No  
 Use of Factory Components  Yes  No  
 Condition \_\_\_\_\_ Compliance  Yes  No

#### Intermediate Support

Adequate  Yes  No  
 Use of factory components  Yes  No  
 Condition \_\_\_\_\_ Compliance  Yes  No

#### Roof Braces

Required  Yes  No  
 Condition \_\_\_\_\_ Compliance  Yes  No

#### Clearances above roof

	Required	Actual
Vertical	900 mm (36")	_____
Horizontal	3 m (10')	_____

Chimneys must extend 600 mm (24") above obstacles within a horizontal distance of 3 m (10')  
 Compliance  Yes  No

#### Clearance to Combustibles

Required	Actual	Compliance
50 mm (2")	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No

#### Radiation Shields

Installation \_\_\_\_\_ Compliance  Yes  No

*UP TO TODAY'S CODE AS FAR AS CAN BE SEEN  
 NOW ILLIY [Signature] WETT #428*