



Kawartha Home and Hearth Ltd.

Wett Technician: James Barrieau #10867

www.kawarthahomeandhearth.com khh ltd@gmail.com

P.O. Box 21, Bobcaygeon, ON K0M 1A0

(705) 340-2123

Wood Stove, Flue Pipe & Manufactured Chimney

Customer Information:

Name: ~~XXXXXXXXXXXX~~

Address: 84 Greenwood Rd Kirkfield, ON

Email: ~~XXXXXXXXXXXX~~

Phone: ~~XXXXXXXXXX~~

Appliance Make: Haugh's Model: S31105 Serial: 859889

Installation manual available: YES NO Original or Download

Certification Standard: ULC S627 EPA CSA B415 Uncertified Unknown

Listing Agency: ULC CSA WH/ETL OTL Other / Comment:

Alcove Approved: YES NO N/A

Mobile home approved: YES NO N/A

Flue Collar Size: 6"

Is there a fan or blower attached? YES NO

Installed in: Residence Modular home Mobile home Alcove
 Garage Other:

Appliance location: Basement Main floor Other:

Appliance installed by: James Barrieau Wett Technician # 10867

Installation Date: September 21, 2021

Chimney Make / Model # ICC Excel

Installation manual available? YES NO

Listing Agency: ULC CSA WH / ETL OTL

Other

Flue size: 6"



Certification standard: ULC S624 ULC S629 Other: Unknown

Inside installation Outside installation Total height: 13 Feet

Chimney installed by: James Barrieau #10867 Date: September 21, 2021

Unknown

Does the unit share a venting system with another appliance?

YES NO

Clearance to	Uncertified	Certified	Actual	Compliant	Non-Compliant N/A or UTI (un- able to inspect)
Combustible right side wall	36" / 48"				N/A
Combustible left side wall	36" / 48"				N/A
Combustible to rear wall	36" / 48"	13"	13.5"	Yes	
Combustible corner right side 45degree					N/A
Combustible to left side 45 degrees					N/A
Top ceiling	60"	83"		Yes	
Shielding ceiling					N/A
Wall shielding rear					N/A
Wall shielding right side					N/A
Wall shielding left side					N/A
Ember pad material	Continuous durable non- combustible		Metal	Yes	
Ember pad front	18"	18"	20"	Yes	

Ember pad rear	8"	8"	13.5"	Yes	
Ember pad right side	8"	8"	11.5"	Yes	
Ember pad left side	8"	8"	11.5"	Yes	
Outdoor combustible air					N/A
Flue Pipe Connector Requirments	Single Wall	Double Wall	Actual	Compliant	Non Compliant N/A or UTI
Wall clearances right side	18 inches	6 inches			N/A
Wall clearances left side	18 inches	6 inches			N/A
Wall clearances rear wall	18 inches	6 inches	8 inches	Yes	

Flue Pipe Connector Re-quirements	Single Wall	Double Wall	Actual	Compliant	Non Compliant N/A or UTI
Clearances to the ceiling	18"	6"			N/A
Total length	Max 10'		5'	Yes	
Elbows	Max 180 degree		2	Yes	
Fastening	3 screws			Yes	
Allowance for expansion	Elbow / slip / adjust			Yes	
Flue pipe orientation	Male end down			Yes	
Flue pipe slope	Min ¼" per foot				N/A

Flue Pipe Connector Requirements	Required YES	Not Required NO	Actual	Compliant	Non Compliant N/A or UTI
Pipe Shielding					N/A
Support horizontal					N/A
Wall radiation shield					N/A
Clean-out tee and cap					N/A
Base tee & cap					N/A
Wall support / band					N/A
Distance between supports					N/A
Chimney offsets					N/A
Offset support					N/A
Firestopping				Yes	
Ceiling support				Yes	

Flue Pipe Connector Requirements	Required YES	Not Required NO	Actual	Compliant	Non Compliant N/A or UTI
Attic radiation shield					N/A
Roof flashing / storm collar				Yes	

Rain cap				Yes	
Roof braces				Yes	
Height above roof surface	Requires min 900mm 3'36"		10'	Yes	

